



SAFETY ASSESSMENT
FEDERATION

Guidance

In-Service Inspection Procedures

Lift Machine Room Guarding Requirements

REFERENCE: MLCC02 - IRELAND
ISSUE: 03
DATE: 16/02/21

DOCUMENT INFORMATION:

REFERENCE:	MLCC 02 - IRELAND
ISSUE:	03
DATE:	16/02/21
PREPARED BY:	Machinery Lift and Crane Committee (TC 2)
APPROVED BY:	TC 2 and TSC

DOCUMENT HISTORY RECORD:

ISSUE:	DATE:	CHANGE DETAIL:
03	16/02/21	Review

© The Safety Assessment Federation Ltd

All rights reserved. Except for normal review purposes, no part of this publication may be reproduced, utilised, stored in a retrieval system or transmitted in any form by any means electronic or mechanical, including photocopying, recording or by any information, storage or retrieval system without the written permission of the publisher.

CONTENTS

SITUATION 1

GUIDANCE..... 1

SITUATION

What is the procedure adopted by SAFed members when making recommendations concerning the guarding of machinery within the lift machine room?

GUIDANCE

The need to undertake measures with respect to the guarding of dangerous parts of machinery in lift machine rooms, as required by the Safety, Health and Welfare at Work (General Application) Regulations 2007 Regulation 33, should be identified as a result of a risk assessment specified by the Safety, Health and Welfare at Work Act 2005 regulation 19. This requires that there should be a risk assessment undertaken in relation to duty holder, to identify all associated risk in relation to the machine room, the Competent Persons could be asked to carry this out on behalf of the duty holder. This risk assessment may validly consider the expertise of those who work in lift machine rooms and the relatively small number of reported accidents involving them. If additional control measures are required as an outcome of the risk assessment, then these should indicate the priority to be given to their provision. A phased programme of improvement would normally be acceptable.

In order to help ensure that there is a consistent approach to undertaking this risk assessment, SAFed members are encouraged to follow the procedure as outlined below.

The following information should be recorded:

Clients Name

Clients Address

Client Number

Lift Identification Number

Address where lift is installed

Name of Engineer Surveyor undertaking risk assessment

Date of risk assessment

Date of next risk assessment

Risk assessment reference number

Complete the following questions. If the answer to any of the questions is no, then guards should be fitted unless appropriate corrective actions are taken.

Question	Yes	No	Control Measures Required
<p>Access to machine room</p> <p>Are all access doors and hatches locked and keys under the control of a responsible person?</p>			
<p>Machinery isolation</p> <p>Is there a safe and adequate means to isolate the equipment for maintenance/inspection work?</p>			
<p>Lighting</p> <p>Is the level of normal (200 lux) and emergency lighting adequate?</p>			
<p>Access to equipment/fall hazard</p> <p>Is there safe and adequate means of access to maintain/inspect the equipment?</p> <p>If the equipment is mounted on a plinth, is there safe and adequate means of access and is the perimeter protected?</p>			
<p>Moving parts</p> <p>Are all exposed moving parts of the lift machinery painted yellow and a stop device located adjacent to the moving parts of the equipment?</p>			
<p>Housekeeping</p> <p>Is the standard of housekeeping good? I.e. is the machine room clean and free of rubbish and dust?</p>			
<p>Work practices</p> <p>Do maintenance/inspection personnel have to work in isolation?</p> <p>If so are you satisfied that there is adequate backup in the event of an accident/incident?</p>			
<p>Other services</p> <p>Is the lift machine room used solely for the lift installation? I.e. no other utility services installed or accessed through the lift machine room? e.g. water, communications etc.</p>			